


- NOTES:
1. EXPANSION JOINTS AT EACH SIDE OF DRIVEWAY APPROACH. SEE STD. DRWG. NO. 101.
 2. USE CLASS B CONCRETE (5 SACK MIX) MINIMUM.
 3. CURB AND GUTTER SHALL NOT BE POURED MONOLITHIC WITH SIDEWALK.
 4. DRIVEWAY APPROACH AND GUTTER SECTION MAY BE POURED MONOLITHIC.
 5. AGGREGATE BASE SHALL BE COMPACTED TO A MINIMUM OF 95% RELATIVE COMPACTION.



DESIGN AND CONSTRUCTION STANDARDS

DRIVEWAY APRON WITH CONTINUOUS SIDEWALK

[Signature]

TIM ERIKSEN, PUBLIC WORKS DIRECTOR / CITY ENGINEER

DRAWING NO.

103

DRAWN BY: A.S.

JAN. 2019 - NTS