



NOTES (See STD. DRG. NO. 102.)

1. Weakened Plane - 1/8" Wide x 1" Deep in sidewalk, 1/8" Wide x 1-1/2" Deep in curb and gutter. (10' on center)
2. Expansion Joints - Material to be 1/2" thick premolded joint filler, full thickness of concrete. Approved mechanical joints may be used in walks in lieu of expansion joints. Expansion joints shall be placed in the sidewalk at the same location as those in the curb and gutter, when the sidewalk is adjacent to the curb and gutter, unless otherwise directed by the Engineer. Distance between joints 60 feet. Expansion joints shall be installed in the curb & gutter at all curb returns, and also at all driveways.
3. Score Marks - In sidewalk 5' on center. In sidewalk 6' or more in width, longitudinal score marks along center of walk. In areas with existing sidewalk, score marks to match existing, or shall meet the approval of the City Engineer.
4. Class "B" concrete shall be used.
5. Relative compaction for aggregate base material 90%
6. Weakened Plane shall be made at both sides of vaults and catch basins from back of curb to back of sidewalk.

CITY OF UKIAH			
SCORE MARK DETAILS FOR SIDEWALK, CURB, CURB & GUTTER			
Scale: NONE	Drawn By: ML	Approved By: <i>[Signature]</i>	Drawing No.
Date: 6-13-95	Revised: 8-90	<i>[Signature]</i>	101