



NOTES

1. LATERAL PIPE TO BE 4" I.D. MINIMUM, AND ONE OF THE FOLLOWING MATERIALS:
 - A) CAST IRON PIPE
 - B) ASBESTOS CEMENT PIPE, CLASS 2400
 - C) POLYVINYL CHLORIDE (PVC), SDR-35
2. 2% MINIMUM SLOPE GRADE EXCEPT WHERE A VARIATION IS SPECIFICALLY APPROVED BY THE CITY ENGINEER.
3. DEPTH OF SERVICE LATERAL AT RIGHT OF WAY, IN NO CASE, SHALL BE LESS THAN 3', HOWEVER SUFFICIENT DEPTH SHALL BE PROVIDED TO ADEQUATELY SERVE THE BUILDING SITE.
4. IN SOME CASES, THE ENGINEER MAY BE REQUIRED TO STAKE THE LATERAL INVERT AT RIGHT OF WAY.
5. MINIMUM INVERT ELEVATION OF WYE BRANCH EQUALS CENTERLINE OF SEWER MAIN.
6. FOR SERVICE LATERAL TRENCH DETAILS SEE STANDARD DRAWING NO. 220.

CITY OF UKIAH			
SEWER SERVICE LATERAL (INITIAL CONSTRUCTION)			
Scale: No Scale	Drawn By: ML	Approved By: <i>4/88</i>	Drawing No.
Date: 1/2/87	Revised:	<i>R. Pedroncelli</i>	210