



NOTE

1. ALL SEWERS MUST GRAVITY FLOW TO THE SEWER MAIN.  
NO DIRECT CONNECTIONS WILL BE ALLOWED ON TRUNK SEWERS  
AND SOME INTERCEPTOR SEWERS.
2. THE DISCHARGE LINE FROM AN EJECTOR, PUMP, OR OTHER  
MECHANICAL DEVICE SHALL BE PROVIDED WITH AN ACCESSIBLE  
BACKWATER VALVE AND GATE VALVE (UPC SECTION 409).
3. CONSTRUCTION DETAILS, SLOPE, AND MATERIALS CONFORM TO DRW. 210.
4. ANY ALTERNATE DESIGN MUST BE SUBMITTED FOR APPROVAL.

# CITY OF UKIAH

SINGLE FAMLY DWELLING  
PRIVATE FORCE MAIN

SCALE : NONE	APPROVAL DATE :	DRAWN BY	TM
DATE : 5-21-96	APPROVED BY : <i>May 23, 1996</i>	REVISED	
SHEET NO.		DRAWING NO	215