



1. Wire fabric shall be 4' long (min.). Width shall equal sidewalk width minus 4".
2. On site drainage and location of curb outlets shall be by owner to the satisfaction of City Engineer.
3. Drain culvert shall have minimum of 2" concrete cover at back of sidewalk.
4. Sidewalk drain shall be 3" x 6" wide minimum or multiple drains may be used where required.
5. Drains shall be welded steel plates, 1/8" thick.
6. When constructing drain within existing sidewalk, remove and replace to the nearest score marks. Also, remove and replace curb to same score marks. (At contractor's option, gutter shall be removed with curb or left in place by sawcutting along gutter flowline.)
7. Refer to STD. DRG. NO. 102 for additional notes on curb & gutter.

CITY OF UKIAH

UNDER SIDEWALK DRAIN

Scale: NO SCALE	Drawn By: ML	Approved By:	Drawing No.
Date: 12/04/87	Revised:	<i>R. Pedroncelli</i>	410